

PROFORMA FOR SAFE DRINKING WATER AND SANITARY
CONDITION CERTIFICATE


No. 135

Dated: 07/02/2024

It is certified that an inspection team headed by Dr Navreet Kaur, Medical Officer (PCMS-I), PHC Varpal from Department of Health and Family Welfare, Punjab inspected the Goodwill International School, VPO Dhadiala Natt, Tehsil Batala, District Gurdaspur, Punjab on 07/02/2024, checked the water test report submitted by the school and found that the school has potable drinking water for students and staff of the institution and is having provision for running water in the toilets and maintaining hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

The above is valid for a period of one year

Signature with Seal


Medical Officer (PCMS-I)
PHC VARPAL
Name: Dr. Navreet Kaur

Designation: Medical Officer
(PCMS-I)
PHC Varpal

Name & Address of the Office
Department : Department of Health
and Family Welfare, Punjab

To

Goodwill International School

VPO Dhadiala Natt
Tehsil Batala
Distt. Gurdaspur


Chairman

Goodwill International School
Dhadiala Natt, Distt. Gurdaspur (Pb.)
CBSE Affi. No. 1631115


Principal

Goodwill International School
Dhadiala Natt, Distt. Gurdaspur (Pb.)
CBSE Aff. No. 1631115, Code-21103

BLOCK WATER TESTING LABORATORY, BATALA

Judicial Court Complex on Police line Road, Opposite Police Station, Batala.
bwtlbt@gmail.com


TEST REPORT		
Name & Address of Customer : GOODWILL INTERNATIONAL SCHOOL dhadiala natt batala	Customer Reference No.	No : 98 Dated : 22/05/2023
	Sample Submitted by	PRINCIPAL
	Date of Sample Receipt	22/05/2023
	Analysis Starting Date	22/05/2023
	Analysis completion Date	26/05/2023

Discipline : Chemical Testing	Group: Water
ULR No.: NABLDWT0026023152F	Sample Type : Water
Test Report No.: BWTLBTL/2324/00096	Date of Issue : 26/05/2023
Registration no.: BWTLBTL/REG2324/00200	Condition of Sample : Unsealed
Collection Point: Private Submersible	Quantity/Type of Bottle: 1000 ml / Plastic Bottles
Scheme/Source: Not Mentioned(Not Mentioned)	Location/Depth : village / 350 ft
Village : Diwaniwal	Habitation : Diwaniwal
Block: Batala	District : Gurdaspur
Latitude : Not Mentioned	Longitude: Not Mentioned


Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	pH	7.01	6.5-8.5	No Relaxation	--	IS 3025 (Part 11-1993) Electrometric Method
2	Colour	2	5	15	CU	IS 3025(Part 4-2021) Visual Comparison Method
3	Odour	agreeable	Agreeable	Agreeable	--	IS 3025 (Part 5 – 2018) (Second Revision)
4	Taste	agreeable	Agreeable	Agreeable	--	IS 3025 (Part 8 – 1984) (RA 2017)
5	TDS	330	500	2000	mg/l	IS 3025 (Part 16-1984) Gravimetric Method
6	Turbidity	0.40	1	5	NTU	IS 3025 (Part 10-1984) Nephelometric Method
7	Alkalinity	138	200	600	mg/l	IS 3025 (Part 23-1986) Indicator Method
8	Hardness	152	200	600	mg/l	IS 3025 (Part 21- 2019) EDTA Method
9	Calcium	24	75	200	mg/l	IS 3025 (Part 40-1991) EDTA Titrimetric Method
10	Magnesium	24.3	30	100	mg/l	APHA (23rd Ed.2017) Method: 3500-Mg+2 B By Calculation Method
11	Chloride	14	250	1000	mg/l	IS 3025 (Part 32-1988) Argentometric Method

This Report is issued under the following terms & Condition :

1. The results apply to the sample as received only.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part and can't be used as evidence in court of law.
4. Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed), ND=Not Detected
5. * Value not available or test not performed for this parameter.
6. Temperature condition limit: 25±5°C and Humidity condition limit:50 ±20%


Principal
Goodwill International School
Dhadiala Natt, Distt. Gurdaspur (Pb.)
CBSE Aff. No. 1631115, Code-21103


Chairman
Goodwill International School
Dhadiala Natt, Distt. Gurdaspur (Pb.)
CBSE Affi. No. 1631115


Mr. Pankaj Kumar
Quality Manager
Authorized Signatory
For,Block Water Testing Laboratory, Batala

----- End of the Test Report -----